



INVITATION TO BID

The City of Paris will receive proposals until 10:00 AM on Monday September 15, 2025, or the lift station submersible pump. Specifications and other related information may be obtained from the undersigned at 525 High Street, Paris, KY 40361, during normal working hours or by visiting the City of Paris website:
<https://paris.ky.gov/CurrentBidOpenings.aspx>

Sealed bids should be delivered to the attention of the City of Paris Purchasing Manager no later than Monday September 15, 2025 at 10:00 AM. Bids shall be clearly marked "WWTP Lift Station Submersible Pump". The City reserves the right to reject any and all proposals.

Michael Harris, Superintendent
Waste Water Treatment Plant
525 High Street
Paris, KY 40361
(859) 987-2110
mharris@paris.ky.gov

Specifications

Keen Pump

K8VK750M4-43

75 HP 460/3, 1750 RPM, 8" Discharge, 2-vane enclosed impeller, 70' cords

316 SST Volute Wear Ring

410 SST impeller wear ring

12.25 x 11.25" impeller

Rated for 3,000 GPM @ 64' TDH

Must list approximate current lead times